

ARNOT POWER STATION

CHEMICAL ANALYSIS : TRIHALOMETHANES

Date Received : 11 October 2011

Analysis Results - µg/l [ppb]	Arnot Power Station
Bromoform	<5
Chloroform	16
Bromodichloromethane	<10
Dibromochloromethane	<2
Trichloroethylene (TCE)	<5

ppb - parts per billion

STANDARDS 241 (2006)	
Class 1 (acceptable)	< 200 µg/l
Class 2 (max. allowable)	200 - 300 µg/l

P.L.G. UYS (M.D.)