

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
P.O. Box / Posbus 8328
WITBANK 1035
Web: www.regenwaters.com

Tel.: 013-690-1487
Fax / Faks: 013-656-5050
E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS TRIHALOMETHANE COMPOUNDS (THM)

SAMPLE INFORMATION		LAB NUMBER	C46.D
DATE RECEIVED	20-Nov-12	DATE ANALYZED	7-Dec-12
CLIENT	Steve Tshwete Municipality	MATRIX	Water
SAMPLE NAME	Doornkop 1		
CONTAINER	Plastic, polyethylene		
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Extraction		

COMPOUND	CONCENTRATION	UNITS
Chloroform	14.91	µg/liter
Bromodichloromethane	<10	µg/liter
Trichloroethene	<10	µg/liter
Dibromochloromethane	<10	µg/liter
Bromoform	<10	µg/liter

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Trihalomethane Result Interpretation


According to the South African National Standards 241-1: Ed1 2011 the limits for trihalomethane content in drinking water are:

Compound	Concentration	Units
Chloroform	≤300	µg/liter
Bromoform	≤100	µg/liter
Dibromochloromethane	≤100	µg/liter
Bromodichloromethane	≤60	µg/liter
Trichloroethene*	≤20	µg/liter

*Standard from the world health organization drinking water standard 2011 (Not technically a THM but is a frequently requested compound in conjunction with THM analysis.)

Trihalomethanes in potable water is a by-product of disinfection using chlorine and other disinfectants. The concentration of trihalomethanes in potable water needs to be monitored, as long term consumption of high concentrations can lead to chronic ailments.

The sample submitted **Steve Tshwete Municipality Doornkop 1** complies with the standards for trihalomethane content in drinking water.



P.L.G. JYS (M.D)

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
P.O. Box / Posbus 8328
WITBANK 1035
Web: www.regenwaters.com

Tel.: 013-690-1487
Fax / Faks: 013-656-5050
E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS TRIHALOMETHANE COMPOUNDS (THM)

SAMPLE INFORMATION		LAB NUMBER	C47.D
DATE RECEIVED	20-Nov-12	DATE ANALYZED	7-Dec-12
CLIENT	Steve Tshwete Municipality	MATRIX	Water
SAMPLE NAME	Doornkop 2		
CONTAINER	Plastic, polyethylene		
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Extraction		

COMPOUND	CONCENTRATION	UNITS
Chloroform	<10	µg/liter
Bromodichloromethane	<10	µg/liter
Trichloroethene	<10	µg/liter
Dibromochloromethane	<10	µg/liter
Bromoform	<10	µg/liter

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Trihalomethane Result Interpretation


According to the South African National Standards 241-1: Ed1 2011 the limits for trihalomethane content in drinking water are:

Compound	Concentration	Units
Chloroform	≤300	µg/liter
Bromoform	≤100	µg/liter
Dibromochloromethane	≤100	µg/liter
Bromodichloromethane	≤60	µg/liter
Trichloroethene*	≤20	µg/liter

*Standard from the world health organization drinking water standard 2011 (Not technically a THM but is a frequently requested compound in conjunction with THM analysis.)

Trihalomethanes in potable water is a by-product of disinfection using chlorine and other disinfectants. The concentration of trihalomethanes in potable water needs to be monitored, as long term consumption of high concentrations can lead to chronic ailments.

The sample submitted **Steve Tshwete Municipality Doornkop 2** complies with the standards for trihalomethane content in drinking water.


P.L.G UYS (M.D)

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
P.O. Box / Posbus 8328
WITBANK 1035
Web: www.regenwaters.com

Tel.: 013-690-1487
Fax / Faks: 013-656-5050
E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS

TRIHALOMETHANE COMPOUNDS (THM)

SAMPLE INFORMATION		LAB NUMBER	C48.D
DATE RECEIVED	20-Nov-12	DATE ANALYZED	7-Dec-12
CLIENT	Steve Tshwete Municipality	MATRIX	Water
SAMPLE NAME	Kranspoort Rou		
CONTAINER	Plastic, polyethylene		
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Extraction		

COMPOUND	CONCENTRATION	UNITS
Chloroform	<10	µg/liter
Bromodichloromethane	<10	µg/liter
Trichloroethene	<10	µg/liter
Dibromochloromethane	<10	µg/liter
Bromoform	<10	µg/liter

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Trihalomethane Result Interpretation


According to the South African National Standards 241-1: Ed1 2011 the limits for trihalomethane content in drinking water are:

Compound	Concentration	Units
Chloroform	≤300	µg/liter
Bromoform	≤100	µg/liter
Dibromochloromethane	≤100	µg/liter
Bromodichloromethane	≤60	µg/liter
Trichloroethene*	≤20	µg/liter

*Standard from the world health organization drinking water standard 2011 (Not technically a THM but is a frequently requested compound in conjunction with THM analysis.)

Trihalomethanes in potable water is a by-product of disinfection using chlorine and other disinfectants. The concentration of trihalomethanes in potable water needs to be monitored, as long term consumption of high concentrations can lead to chronic ailments.

The sample submitted **Steve Tshwete Municipality Kranspoort Rou** complies with the standards for trihalomethane content in drinking water.



P.L.G UYS (M.D)

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4

P.O. Box / Posbus 8328

WITBANK 1035

Web: www.regenwaters.com

Tel.: 013-690-1487

Fax / Faks: 013-656-5050

E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS TRIHALOMETHANE COMPOUNDS (THM)

SAMPLE INFORMATION

DATE RECEIVED	20-Nov-12	LAB NUMBER	C49.D
CLIENT	Steve Tshwete Municipality	DATE ANALYZED	7-Dec-12
SAMPLE NAME	Kranspoort	MATRIX	Water
CONTAINER	Plastic, polyethylene		
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Extraction		

COMPOUND	CONCENTRATION	UNITS
Chloroform	40.03	µg/liter
Bromodichloromethane	<10	µg/liter
Trichloroethene	<10	µg/liter
Dibromochloromethane	<10	µg/liter
Bromoform	<10	µg/liter

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Trihalomethane Result Interpretation


According to the South African National Standards 241-1: Ed1 2011 the limits for trihalomethane content in drinking water are:

Compound	Concentration	Units
Chloroform	≤300	µg/liter
Bromoform	≤100	µg/liter
Dibromochloromethane	≤100	µg/liter
Bromodichloromethane	≤60	µg/liter
Trichloroethene*	≤20	µg/liter

*Standard from the world health organization drinking water standard 2011 (Not technically a THM but is a frequently requested compound in conjunction with THM analysis.)

Trihalomethanes in potable water is a by-product of disinfection using chlorine and other disinfectants. The concentration of trihalomethanes in potable water needs to be monitored, as long term consumption of high concentrations can lead to chronic ailments.

The sample submitted Steve Tshwete Municipality Kranspoort complies with the standards for trihalomethane content in drinking water.



P.L.G UYS (M.D)