

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
P.O. Box / Posbus 8328
WITBANK 1035
Web: www.regenwaters.com

Tel.: 013-690-1487
Fax / Faks: 013-656-5050
E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS

TRICHALOMETHANE COMPOUNDS (THM)

SAMPLE INFORMATION		LAB NUMBER	D221.D
DATE RECEIVED	27-Sep-13	DATE ANALYZED	2-Oct-13
CLIENT	Steve-Tswete	MATRIX	Water
SAMPLE NAME	Bankfontein		
CONTAINER	Plastic		
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Extraction		

COMPOUND	CONCENTRATION	UNITS
Chloroform	<10	µg/liter
Trichloroethene	<10	µg/liter
Bromodichloromethane	<10	µg/liter
Dibromochloromethane	<10	µg/liter
Bromoform	<10	µg/liter

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Trihalomethane Result Interpretation

According to the South African National Standards 241-1: Ed1 2011 the limits for trihalomethane content in drinking water are:

Compound	Concentration	Units
Chloroform	≤300	µg/liter
Bromoform	≤100	µg/liter
Dibromochloromethane	≤100	µg/liter
Bromodichloromethane	≤60	µg/liter
Trichloroethene*	≤20	µg/liter

*Standard from the world health organization drinking water standard 2011 (Not technically a THM but is a frequently requested compound in conjunction with THM analysis.)

Trihalomethanes in potable water is a by-product of disinfection using chlorine and other disinfectants. The concentration of trihalomethanes in potable water needs to be monitored, as long term consumption of high concentrations can lead to chronic ailments.

The sample submitted **Steve-Tswete Bankfontein** complies with the standards for trihalomethane content in drinking water.



P.L.G UYS (M.D)

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
P.O. Box / Posbus 8328
WITBANK 1035
Web: www.regenwaters.com

Tel.: 013-690-1487
Fax / Faks: 013-656-5050
E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS

SCREENING FOR PHENOLIC COMPOUNDS

SAMPLE INFORMATION

DATE RECEIVED	27-Sep-13	LAB NUMBER	D221.D
CLIENT	Steve-Tswete	DATE ANALYZED	4-Oct-13
SAMPLE NAME	Bankfontein	MATRIX	Water
CONTAINER	Plastic	DILUTION FACTOR	No Dilution
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Microextraction		

COMPOUND	CONCENTRATION	UNITS
phenol	<10	µg/liter
2-chlorophenol	<10	µg/liter
2-methylphenol	<10	µg/liter
3+4-methylphenol	<10	µg/liter
2-nitrophenol	<10	µg/liter
2,4-dimethylphenol	<10	µg/liter
2,4-dichlorophenol	<10	µg/liter
2,6-dichlorophenol	<10	µg/liter
4-chloro-3-methylphenol	<10	µg/liter
2,3,5-trichlorophenol	<10	µg/liter
2,4,6-trichlorophenol	<10	µg/liter
2,4,5-trichlorophenol	<10	µg/liter
2,3,4-trichlorophenol	<10	µg/liter
2,3,6-trichlorophenol	<10	µg/liter
2,3,4,6-tetrachlorophenol	<10	µg/liter
2,3,5,6-tetrachlorophenol	<10	µg/liter
3,4,5-trichlorophenol	<10	µg/liter
pentachlorophenol	<10	µg/liter
DINOSEB	<10	µg/liter
TOTAL IDENTIFIED	<10	µg/liter

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Results marked "ND" - concentration outside of calibration range, estimate only.


P.L.G. UYS (M.D)

Page 1 of 1

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
P.O. Box / Posbus 8328
WITBANK 1035
Web: www.regenwaters.com

Tel.: 013-690-1487
Fax / Faks: 013-656-5050
E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS

TRIHALOMETHANE COMPOUNDS (THM)

SAMPLE INFORMATION		LAB NUMBER	D222.D
DATE RECEIVED	27-Sep-13	DATE ANALYZED	2-Oct-13
CLIENT	Steve-Tswete	MATRIX	Water
SAMPLE NAME	Kranspoort Raw		
CONTAINER	Plastic		
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Extraction		

COMPOUND	CONCENTRATION	UNITS
Chloroform	<10	µg/liter
Trichloroethene	<10	µg/liter
Bromodichloromethane	<10	µg/liter
Dibromochloromethane	<10	µg/liter
Bromoform	<10	µg/liter

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Trihalomethane Result Interpretation

According to the South African National Standards 241-1: Ed1 2011 the limits for trihalomethane content in drinking water are:

Compound	Concentration	Units
Chloroform	≤300	µg/liter
Bromoform	≤100	µg/liter
Dibromochloromethane	≤100	µg/liter
Bromodichloromethane	≤60	µg/liter
Trichloroethene*	≤20	µg/liter

*Standard from the world health organization drinking water standard 2011 (Not technically a THM but is a frequently requested compound in conjunction with THM analysis.)

Trihalomethanes in potable water is a by-product of disinfection using chlorine and other disinfectants. The concentration of trihalomethanes in potable water needs to be monitored, as long term consumption of high concentrations can lead to chronic ailments.

The sample submitted **Steve-Tswete Kranspoort Raw** complies with the standards for trihalomethane content in drinking water.



P.L.G UYS (M.D)

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
P.O. Box / Posbus 8328
WITBANK 1035
Web: www.regenwaters.com

Tel.: 013-690-1487
Fax / Faks: 013-656-5050
E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS

SCREENING FOR PHENOLIC COMPOUNDS

SAMPLE INFORMATION

DATE RECEIVED	27-Sep-13	LAB NUMBER	D222.D
CLIENT	Steve-Tswete	DATE ANALYZED	4-Oct-13
SAMPLE NAME	Kranspoort Raw	MATRIX	Water
CONTAINER	Plastic	DILUTION FACTOR	No Dilution
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Microextraction		

COMPOUND	CONCENTRATION	UNITS
----------	---------------	-------

phenol	<10	µg/liter
2-chlorophenol	<10	µg/liter
2-methylphenol	<10	µg/liter
3+4-methylphenol	<10	µg/liter
2-nitrophenol	<10	µg/liter
2,4-dimethylphenol	<10	µg/liter
2,4-dichlorophenol	<10	µg/liter
2,6-dichlorophenol	<10	µg/liter
4-chloro-3-methylphenol	<10	µg/liter
2,3,5-trichlorophenol	<10	µg/liter
2,4,6-trichlorophenol	<10	µg/liter
2,4,5-trichlorophenol	<10	µg/liter
2,3,4-trichlorophenol	<10	µg/liter
2,3,6-trichlorophenol	<10	µg/liter
2,3,4,6-tetrachlorophenol	<10	µg/liter
2,3,5,6-tetrachlorophenol	<10	µg/liter
3,4,5-trichlorophenol	<10	µg/liter
pentachlorophenol	<10	µg/liter
DINOSEB	<10	µg/liter

TOTAL IDENTIFIED	<10	µg/liter
-------------------------	---------------	-----------------

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Results marked "N" - concentration outside of calibration range, estimate only.



P.L.G. UYS (M.D)

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
P.O. Box / Posbus 8328
WITBANK 1035
Web: www.regenwaters.com

Tel.: 013-690-1487
Fax / Faks: 013-656-5050
E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS

TRICHALOMETHANE COMPOUNDS (THM)

SAMPLE INFORMATION		LAB NUMBER	D223.D
DATE RECEIVED	27-Sep-13	DATE ANALYZED	2-Oct-13
CLIENT	Steve-Tswete	MATRIX	Water
SAMPLE NAME	Kranspoort		
CONTAINER	Plastic		
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Extraction		

COMPOUND	CONCENTRATION	UNITS
Chloroform	<10	µg/liter
Trichloroethene	<10	µg/liter
Bromodichloromethane	<10	µg/liter
Dibromochloromethane	<10	µg/liter
Bromoform	<10	µg/liter

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Trihalomethane Result Interpretation

According to the South African National Standards 241-1: Ed1 2011 the limits for trihalomethane content in drinking water are:

Compound	Concentration	Units
Chloroform	≤300	µg/liter
Bromoform	≤100	µg/liter
Dibromochloromethane	≤100	µg/liter
Bromodichloromethane	≤60	µg/liter
Trichloroethene*	≤20	µg/liter

*Standard from the world health organization drinking water standard 2011 (Not technically a THM but is a frequently requested compound in conjunction with THM analysis.)

Trihalomethanes in potable water is a by-product of disinfection using chlorine and other disinfectants. The concentration of trihalomethanes in potable water needs to be monitored, as long term consumption of high concentrations can lead to chronic ailments.

The sample submitted **Steve-Tswete Kranspoort** complies with the standards for trihalomethane content in drinking water.



P.L.G UYS (M.D)

REGEN WATERS

LABORATORY • LABORATORIUM

CK. 89/14418/23

4 Woltemade Street / Woltemadestraat 4
 P.O. Box / Posbus 8328
 WITBANK 1035
 Web: www.regenwaters.com

Tel.: 013-690-1487
 Fax / Faks: 013-656-5050
 E-mail / Epos: regenlab@mweb.co.za

CERTIFICATE OF ANALYSIS

SCREENING FOR PHENOLIC COMPOUNDS

SAMPLE INFORMATION

DATE RECEIVED	27-Sep-13	LAB NUMBER	D223.D
CLIENT	Steve-Tswete	DATE ANALYZED	4-Oct-13
SAMPLE NAME	Kranspoort	MATRIX	Water
CONTAINER	Plastic	DILUTION FACTOR	No Dilution
INSTRUMENT	Agilent 7890A GC/MS, Headspace 7697A, Solid Phase Microextraction		

COMPOUND	CONCENTRATION	UNITS
----------	---------------	-------

phenol	<10	µg/liter
2-chlorophenol	<10	µg/liter
2-methylphenol	<10	µg/liter
3+4-methylphenol	<10	µg/liter
2-nitrophenol	<10	µg/liter
2,4-dimethylphenol	<10	µg/liter
2,4-dichlorophenol	<10	µg/liter
2,6-dichlorophenol	<10	µg/liter
4-chloro-3-methylphenol	<10	µg/liter
2,3,5-trichlorophenol	<10	µg/liter
2,4,6-trichlorophenol	<10	µg/liter
2,4,5-trichlorophenol	<10	µg/liter
2,3,4-trichlorophenol	<10	µg/liter
2,3,6-trichlorophenol	<10	µg/liter
2,3,4,6-tetrachlorophenol	<10	µg/liter
2,3,5,6-tetrachlorophenol	<10	µg/liter
3,4,5-trichlorophenol	<10	µg/liter
pentachlorophenol	<10	µg/liter
DINOSEB	<10	µg/liter


TOTAL IDENTIFIED	<10	µg/liter
-------------------------	---------------	-----------------

Samples stored at 5°C after acceptance by Regen Waters.

This report is only applicable to the sample provided for testing.

Regen Waters cannot be held accountable for any errors that might have been caused by improper sampling, handling or storage of samples prior to acceptance.

Results marked "*" - concentration outside of calibration range, estimate only.



P.L.G. UYS (M.D)